

**WRWSD SEWER SERVICE AGREEMENT
PHASE I**

I, _____, request Waynoka Regional Water and Sewer District to install a sewer service consisting of grinder pump, discharge line, and accessories for Lot # _____, for which I agree to pay \$5500.00 installation fee and \$2000.00 tap-in fee, for a total sum of \$7500.00. **NOTE: Sewage discharge line in excess of 100 feet will be billed to the customer at a cost of \$3.00 per foot.** (Effective 2-3-98) A properly executed and recorded easement has been completed along with a plot plan (copies attached), for the purpose of installation and maintenance of said sewer service. In addition, I have received and read the plumbing code requirements of the Waynoka Property Owners Association, Inc. Building Code along with the specific requirements of the Waynoka Regional Water and Sewer District concerning said sewer service connections listed elsewhere on this page.

Date: _____ Signed: _____

Amount of Payment: _____ Form of Payment: _____

Personnel receiving this signed agreement: _____

Sewer lines must be shown on plot plan.
* Location of Sewer Grinder Pump is:

**SAMPLE FORM - FOR INFORMATION ONLY
PICK-UP USABLE COPY AT WPOA OFFICE**

*Is copy of plot plan attached with this agreement? _____

*Is copy of easement attached with this agreement? _____

NOTICE:

**NO WATER OR SEWER TAPS/INSTALLATIONS WILL OCCUR UNTIL ROUGH GRADING
AND CONSTRUCTION DEBRIS IS REMOVED FROM PROPERTY.**

**SEWER USAGE WILL BE BILLED THE MONTH FOLLOWING INSTALLATION
REGARDLESS OF USE.**

Ohio Utilities Protection Service Reference Number: _____ Date: _____

Comments: _____

SERVICE INSPECTION AND START UP: Lot # _____ Date: _____ Initials: _____

WRWSD CUSTOMER SEWER SERVICE REQUIREMENTS

1. Contact the utility department before beginning construction for proper location of utilities. The utility department is responsible for installing the sewer grinder pump, control panel, 1-1/4" discharge pipe and connections. The sewer grinder pump is to be placed within 10' of dwelling and accessible at all times. The 1-1/4" sewer discharge pipe from the pump to the main shall be installed along a property line. Other underground utilities shall not be permitted to cross the sewer discharge pipe. Variances to the above may be made at the utility departments' discretion.
2. The customer is required to provide a 4" PVC Schedule 40, 2-way cleanout installed adjacent to foundation wall no more than 28" below grade and is required to provide a non-connected 10 foot piece of PVC Schedule 40 pipe.
3. Electric provided by the customer is to be a 12-3 with ground (4 wires) conductor connected to a singularly dedicated 20 amp, double pole breaker inside the customer's house panel breaker box using red and black wires to carry 240 volts a.c. phase to phase, white wire to serve as neutral, and bare wire to serve as ground.
4. 3 feet of wire is to protrude through outside wall, 3 feet above finished grade level and directly over the PVC sewer cleanout. Exceptions may be made at utility departments' discretion and customer's expense. NOTE: The customer is required to provide a 3/4" PVC electrical conduit LB connector, glue type and install said connector over the 12-3 wire in such a manner as to provide 1.5 inch spacing between the outside of the wall and the inside vertical run of the connector. This spacing allows for the proper positioning of the utility grinder pump control panel.

Alternate: If preferred, underground feeder wire (12-3 with ground) (4 wires) may be buried 2 feet deep and fed to the PVC sewer cleanout. A minimum of 6 feet of wire is to be left available above finished grade level. A piece of 3/4" PVC electrical conduit, 6 feet in length, is to be supplied to the utility department by the customer. Wiring is to be inspected by the utility department before backfilling trench.

5. Customer must provide the utility department a copy of their final electrical inspection before the grinder pump is activated.

NOTE: If customer required fittings are not at job site at the time of installation the customer will be billed for any material used by the utility department.

REMINDER: WRWSD Resolution 2009-04 prohibits surface water and other clean water discharge into WRWSD sanitary sewer system

