WRWSD Board of Trustees Saturday Meeting – 6-13/26

Vice President Engle called the meeting to order at 9:30am.
Roll Call: Present: Brumley, Dombroskie, Engle, Gruber, Harper, Mgr. Wilkin
Absent: Feil and Levermore were excused.
Minutes: Approval of the 5/26/26 minutes will be voted on at the 6/29/26 workshop.
President's Report (Levermore):

- Vice President Engle thanked everyone for coming to stay informed.
- Please support the Civic Club by purchasing coffee and donuts this morning.
- We have new Trustee email accounts. Important information will be sent to these new email addresses. This includes financials, Trustee training links and consolidation drafts of WRWSD Rules & Regulations and Bylaws. Please review.
- ACH will be coming soon so be on the lookout for more information.

Treasurer's Report (Feil): Treasurer Feil has reviewed the May financials and found no issues.
Manager and Plant Superintendent Report (Mgr. Wilkin/Supt. Wilson):

- We are working through a few ACH paperwork issues and will roll it out after that is completed.
- There will be a WRWSD plant tour on July 9th from 8a-12p. This is open to all members.
- WRWSD and Russellville regionalization FAQs have been updated and posted on the Lake Waynoka website.
- Mgr. Wilkin addressed the drinking water notice mailed to residents. Over the past year, we were issued a notice of violation from the EPA concerning two frost-free hydrants and shut-off valves in the campground. All issues were fixed but Supt. Wilson failed to notify the EPA of the repairs. The second violation concerned coliform samples. The EPA implemented 40 new samples to be taken and 3-4 were missed. The third violation concerned contact time of chlorine exposure. We need 900 yards and only have 300 yards of piping. Our software records water samples every 15 minutes. The EPA took the worst tests over a few days. So essentially, we only had one violation. The treatment of our water is taken very seriously. Trustee Gruber is the Assistant Director at Clermont County Waterworks and brings years of experience to our community. Bryan stated that the EPA errs on the side of caution and required the public notice to residents. He confirmed that there is nothing wrong with our water. Contrary to social media posts, drinking WRWSD has not been a health hazard.
- The GAC filter medium needs to be replaced to improve the water taste and odor. We will be switching to BCRW in the meantime.

Old Business: None
New Business: None
Motions and Resolutions: None
Board Member Concerns: None
Membership Concerns:

- Kim Kramer would appreciate if water issue notices can be sent to campers since they do not receive water bills.
- Ed Von Lehunder (?) asked why we have our own water system. He feels there are too many regulations. He asked that email blasts and Facebook posts be made when there is a boil advisory. Vice President Engle reiterated that BCRW is unable to provide LW water on a full-time basis. Engle stated that email blasts and Facebook posts are made and encouraged people to contact the office to be added to the email blast. However, we were not on a boil water advisory. Trustee Gruber said that BCRW is a private entity and they cannot be forced to take us on. They are in the process of reserving capacity and will need to upgrade their system too. In the meantime, WRWSD has no choice but to expand our system

Adjournment: The motion to adjourn was made by Dombroskie and seconded by Harper. A yea/nay vote was taken. All were in favor and the meeting was adjourned at 9:53am.

Rhonda J. Maybriar, WRWSD Assistant Recording Secretary